

B&P Surveys

SURVEYING & PLANNING
CONSULTANTS

Office: Tweed Heads
Our Ref: T17021 MES

30th June 2022

LAND & BUILDING
SUBDIVISIONS
•
CONSTRUCTION
•
DEVELOPMENT
CONSULTANTS
•
PLANNING
•
GIS
•
URBAN DESIGN


BODY CORPORATE OF
STRATA PLAN No 63869
83 Gollan Drive, Tweed Heads West

Attention: Lionel Viney

Dear Lionel,

**RE: LEVEL SURVEY
SP63869
GOLLAN DRIVE, TWEED HEADS WEST**

- Average floor level of units 4,8,15 & 27 = **RL 2.98 AHD** (+/-0.01m).
- Average level of mark found describing flood level = **RL 2.05 AHD** (+/- 0.15m).
- Marks found to average floor level = 0.93m approximately.



Yours faithfully,
B & P SURVEYS


M E STANTON
Director

TWEED HEADS
30 Beryl Street
PO Box 327
Tweed Heads NSW 2485
Director
Philip Wyper*

P: (07) 5536 3611
E: tweed@bpsurveys.com.au
W: www.bpsurveys.com.au

NERANG
Ph: (07) 5596 0370
Directors
Keith Savage
Robert Rameka

MURWILLUMBAH
Ph: (02) 6672 1924
Director
Brian Raaen*